



COUNTY OF HENRICO
DEPARTMENT OF PUBLIC UTILITIES



NOTE:

1. PLASTIC SHEET LINER SHALL BE A T-RIBBED POLYVINYL CHLORIDE SHEET MATERIAL. PLASTIC SHEET LINING SHALL CONFORM TO ASTM D 412 AND ASTM D 2240. THE PLASTIC SHEET WITH INTEGRAL T-SHAPED LOCKING EXTENSIONS SHALL BE OF 0.065 INCH MINIMAL THICKNESS WITH LOCKING EXTENSIONS OF 0.375 INCH MINIMUM HEIGHT AND MINIMUM WEB THICKNESS OF 0.085 INCH. THE LOCKING EXTENSIONS SHALL BE SPACED AT 2-1/2 INCHES MAXIMUM SPACING. THE PLASTIC SHEET LINER SHALL BE AMERON T-LOCK, AS MANUFACTURED BY AMERON INTERNATIONAL, BREA, CA; OR EQUAL.



DETAIL A

PLASTIC LINING IN "FLATTOP" TYPE MANHOLE TOP

REVISIONS
06/20/2014

SPECIAL ACID-RESISTANT LINING
ALL MANHOLES

DRWG. NO.
D-210-1