



COUNTY OF HENRICO
DEPARTMENT OF PUBLIC UTILITIES



DOUBLE LEAF ACCESS DOOR WITH LOCK AND LIFT HANDLE (SEE NOTES)



NOTES:

1. LOAD BEARING DOOR SHALL BE BILCO MODEL J H20 OR JD H20 ACCORDING TO SIZE OR APPROVED EQUAL.
2. CONCRETE 4000 PSI MINIMUM.
3. ALL REBAR MEETS ASTM A-615 GRADE 60.

DIMENSIONS		
	4", 6", OR 8" METER	4", 6", OR 8" DGDC DETECTOR ASSEMBLY
A	8'-0"	5'-4"
B	6'-0"	3'-3"
C	4'-6"	3'-8"
D	6'-0"	5'-0"
E	4'-0"	3'-0"
F	2'-0"	1'-8"
G	4", 6", OR 8"	6" OR 8"
H	1'-6"	1'-6"
J	2", 4", OR 6"	NA

REVISIONS
06/20/2014

**METER VAULT
FOR 4", 6", AND 8" METERS/
DGDC DETECTOR ASSEMBLY**

DRWG. NO.
D-555